

Villas West Architectural Specification

Specifications for Installing Gas and Electrical Supplies for Laundry Equipment

Specification No:.....VWAS 15
Issue Date:.....12/21/04
Revision Date:.....New
Revision Level:.....New
Board Approval Date:.....12/21/04
Page:.....1 of 1

General:

When a homeowner has electrical outlets installed to supply power to laundry equipment and a gas line to supply a clothes dryer, the following specifications must be observed.

1. Permits must be obtained from the Pima County Developmental Services for the installation of the electrical outlets and the gas line.
2. Any electrical conductors which must be buried underground to supply laundry equipment shall follow the requirements stated below.
 - Direct buried UF cable shall be buried not less than 24 inches.
 - Conductors in rigid metal or intermediate metal conduit shall be buried not less than 6 inches.
 - Conductors in non-metallic raceway listed for direct burial shall be buried not less than 18 inches.
 - Circuits of 120 volts or less with GFCI protection and maximum over current protection of 20 amperes shall be buried not less than 12 inches.
3. All conductors, where they exit the ground, shall be protected by a suitable raceway, which will be fastened to the building wall.
4. Gas line installations shall comply with current Pima County Plumbing codes, be pressure tested, and inspected by a Pima County inspector.

David L. Howard 12-22-04
Architectural Chairperson Date

Sarah M. Rogers 12-22-04
Documents Chairperson Date

Dean Wenker 12-22-04
CCM Administrator Date

David L. Howard 12-22-04
Association President Date